



Fire Suppression Systems

Restaurant System Specifications

ITEM #	FIRE SUPPRESSION SYSTEM
Quantity:	Lot, (1)
Spec. Manufacturer:	Amerex Corporation, Phone: (205) 655-3271
Spec. Model No.:	Model275/ Model375/Model475, "Zone Defense" (UL-300)
Pertinent Data:	Pressurized thermal responsive tubing detection system
Utilities Required:	120V – 1Ph, 20 Amps;

Furnish and set in place as per manufacturer's standard specs and the following:

GENERAL CONDITIONS:

1. The fire Protection Contractor shall be a Factory Authorized; Factory Trained and State Certified Distributor of the Amerex Corporation general product line. The Fire Protection Contractor must also hold a current Amerex Corporation certificate in a "Zone Defense" training program.
2. The Fire Protection Contractor shall maintain a minimum of a 1-Million Dollar Liability Policy to insure all work performed.
3. All installations must meet current UL-300 criteria; the latest NFPA 96 and NFPA 17A (wet chemical) guidelines.
4. The fire suppression system shall include a minimum 3-year manufacturer's warranty to cover the entire system. The warranty shall be valid only if the system is installed, serviced and maintained by an Amerex authorized distributor in strict accordance with Amerex Manual No. 16640.
5. The Fire Protection Contractor shall include a minimum 1-year installation warranty to cover the entire system.
6. The Fire Protection Contractor shall provide as part of the fire suppression system an Amerex mechanically operated BRASS gas valve. GENERIC GAS SHUT-OFF VALVE SHALL NOT BE ACCEPTABLE- The plumbing contractor shall be responsible for the proper installation of the gas valve.
7. The Fire Protection Contractor shall furnish and install all appliance drops to be penetrating through the top of the hood with a UL-approved Quick Seal device and aimed as directed by the Amerex Corporation.
8. All exposed appliance drops shall be chrome-plated.

9. The General Contractor shall schedule the installation of the recessed remote pull station(s) with the Fire Protection Contractor @ 4'-6" above the finished floor.
10. The Fire Protection Contractor shall provide a dry-contact micro-switch as required to actuate shut-down of the make-up air fan; all energized electrical sources under the hood and signal building fire alarm where fire alarm is present.
11. The fire suppression system's extinguishing agent shall be Amerex KP a liquid fire suppressant, a potassium acetate based solution that suppresses cooking grease fires through both saponification and cooling. The agent shall have a pH of 9 or less and will not harm stainless steel.
12. All related electrical connections and devices shall be provided and installed by the Electrical Contractor.
13. KEC and General Contractor to coordinate with local authorized Amerex Corporation Distributor/Fire Protection Specialist for products, installation, and system certification.
14. Unit shall be housed in stainless steel cabinet. Verify drawing for actual location.

PRODUCT DATA:

1. The Amerex Corporation "Zone Defense" Fire Suppression System is a Patented, pre-engineered, fixed, automatic fire suppression system that when pneumatically activated discharges a fixed amount of wet chemical agent.
2. The system shall be approved for uniform, overlapping appliance protection.
3. The system shall be the pre-engineered type having minimum and maximum guidelines established by the manufacturer and listed by Underwriters Laboratories, Inc. (UL).
4. The manufacturer shall be ISO 9001-2000 registered.
5. The wet chemical agent shall be a specially formulated, aqueous solution of inorganic salts with a pH less than 9 and shall be designed for rapid flame knockdown and foam securement of grease-related fires.
6. Provide all components, including recessed manual pull station(s) as required for a completely operable system.
7. This pre-engineered Amerex Corporation "Zone Defense" fire suppression system shall be warranted for not less than three years from the date that it has been certified for use. (See the Manufacturer's Limited Warranty for further information)
8. Must meet all applicable federal, state and local laws, rules, regulations and codes.